

Contaminant	Violation Y/N	Talladega/Shelby WTPLevel Detected	Shelby Co. South WTP Level Detected	Unit Measurement	MCLG	MCL	Likely Source of Contamination
Turbidity	N	0.5	0.3	Ntu	n/a	TT	Soil runoff
Alpha Emitters	N	<1.0	ND	pCi/l	0	15	Erosion of natural deposits
Combined radium	N	<0.9	ND	pCi/l	0	5	Erosion of natural deposits
Barium	N	21	20	ppb	2000	2000	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
Beryllium	N	.4	0.3	ppb	4	4	Discharge from metal refineries and coal-burning factories; discharge from electrical, aerospace, and defense industries
Chromium	N	1	ND	ppb	100	100	Discharge from steel and pulp mills; Erosion of natural deposits
Copper	N	2.7	40	ppb	1300	AL= 1300	Corrosion of household plumbing; Systems; erosion of natural deposits; Leaching from wood preservatives
Cyanide	N	2.72	ND	ppb	200	200	Discharge from steel/metal factories; discharge from plastic and fertilizer factories
Fluoride	N	1140	1200	ppb	4000	4000	Erosion of natural deposits;water additive which promotes strong teeth;discharge from fertilizer and aluminum factories
Nitrate (as Nitrogen)	N	320	500	ppb	10000	10000	Runoff from fertilizer use; leaching from septic tanks, sewage;erosion of natural deposits
Nitrite (as Nitrogen)	N	236	ND	ppb	1000	1000	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
Di(2-ethylhexyl) adipate	N	ND	2.91	ppb	400	400	Discharge from chemical factories
THHM (RAA) (Total Trihalomethanes)	N	22.5	35	ppb	0	80	By product of drinking water chlorination
HAA5 (RAA)(Haloacetic Acids)	N	20.8	31.4	ppb	0	60	By product of drinking water chlorination
THHM (in distribution system)	N	26-76.7 in Distribution system		ppb	0	80	By product of drinking water chlorination
HAA5 (in distribution system)	N	12-60 in Distribution system		ppb	0	60	By product of drinking water chlorination
TOC (Total Organic Carbon)	N	2.6	2.24	ppm	N/A	TT	Naturally present in the environment

Based on a study conducted by ADEM with the approval of EPA a statewide waiver for the monitoring of asbestos and dioxin was issued. Thus, monitoring for any of these contaminants was not required.

The Talladega/Shelby Water Treatment Plant had a TOC monitoring violation for raw water in the 3rd Quarter of 2009. This was reported to its' customers in a letter on December 21, 2009.

The Talladega/Shelby Water Treatment Plant invested \$15,781.50 in laboratory testing in 2009 to insure the safety of your drinking water. We're proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that some contaminants have been detected. The EPA has determined that your water IS SAFE at these levels.

All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Microbiological Contaminants:

- (1) Total Coliform. Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially-harmful, bacteria may be present. If coliforms were found in more samples than allowed, this would be a warning of potential problems.
- (2) Fecal coliform/E.Coli. Fecal coliforms and E. coli are bacteria whose presence indicates that the water may be contaminated with human or animal wastes. Microbes in these wastes can cause short-term effects, such as diarrhea, cramps, nausea, headaches, or other symptoms. They may pose a special health risk for infants, young children, and people with severely compromised immune systems.
- (3) Turbidity. Turbidity has no health effects. However, turbidity can interfere with disinfection and provide a medium for microbial growth. Turbidity may indicate the presence of disease-causing organisms. These organisms include bacteria, viruses, and parasites that can cause symptoms such as nausea, cramps, diarrhea, and associated headaches.

Radioactive Contaminants:

- (4) Beta/Photon emitters. Certain minerals are radioactive and may emit forms of radiation known as photons and beta radiation. Some people who drink water containing beta and photon emitters in excess of the MCL over many years may have an increased risk of getting cancer.
- (5) Alpha emitters. Certain minerals are radioactive and may emit a form of radiation known as alpha radiation. Some people who drink water containing alpha emitters in excess of the MCL over many years may have an increased risk of getting cancer.
- (6) Combined Radium 226/228. Some people who drink water containing radium 226 or 228 in excess of the MCL over many years may have an increased risk of getting cancer.

Inorganic Contaminants:

- (7) Antimony. Some people who drink water containing antimony well in excess of the MCL over many years could experience increases in blood cholesterol and decreases in blood sugar.
- (8) Arsenic. Some people who drink water containing arsenic in excess of the MCL over many years could experience skin damage or problems with their circulatory system, and may have an increased risk of getting cancer.
- (9) Asbestos. Some people who drink water containing asbestos in excess of the MCL over many years may have an increased risk of developing benign intestinal polyps.
- (10) Barium. Some people who drink water containing barium in excess of the MCL over many years could experience an increase in their blood pressure.
- (11) Beryllium. Some people who drink water containing beryllium well in excess of the MCL over many years could develop intestinal lesions.
- (12) Cadmium. Some people who drink water containing cadmium in excess of the MCL over many years could experience kidney damage.
- (13) Chromium. Some people who use water containing chromium well in excess of the MCL over many years could experience allergic dermatitis.
- (14) Copper. Copper is an essential nutrient, but some people who drink water containing copper in excess of the action level over a relatively short amount of time could experience gastrointestinal distress. Some people who drink water containing copper in excess of the action level over many years could suffer liver or kidney damage. People with Wilson's Disease should consult their personal doctor.
- (15) Cyanide. Some people who drink water containing cyanide well in excess of the MCL over many years could experience nerve damage or problems with their thyroid.
- (16) Fluoride. Some people who drink water containing fluoride in excess of the MCL over many years could get bone disease, including pain and tenderness of the bones. Children may get mottled teeth.
- (17) Lead. Infants and children who drink water containing lead in excess of the action level could experience delays in their physical or mental development. Children could show slight deficits in attention span and learning abilities. Adults who drink this water over many years could develop kidney problems or high blood pressure.
- (18) Mercury (Inorganic). Some people who drink water containing inorganic

- mercury well in excess of the MCL over many years could experience kidney damage.
- (19) Nitrate. Infants below the age of six months who drink water containing nitrate in excess of the MCL could become seriously ill and, if untreated, may die. Symptoms include shortness of breath and blue-baby syndrome.
- (20) Nitrite. Infants below the age of six months who drink water containing nitrite in excess of the MCL could become seriously ill and, if untreated, may die. Symptoms include shortness of breath and blue-baby syndrome.
- (21) Selenium. Selenium is an essential nutrient. However, some people who drink water containing selenium in excess of the MCL over many years could experience hair or fingernail losses, numbness in fingers or toes, or problems with their circulation.
- (22) Thallium. Some people who drink water containing thallium in excess of the MCL over many years could experience hair loss, changes in their blood, or problems with their kidneys, intestines, or liver.

Synthetic organic contaminants including pesticides and herbicides:

- (23) 2,4-D. Some people who drink water containing the weed killer 2,4-D well in excess of the MCL over many years could experience problems with their kidneys, liver, or adrenal glands.
- (24) 2,4,5-TP (Silvex). Some people who drink water containing silvex in excess of the MCL over many years could experience liver problems.
- (25) Acrylamide. Some people who drink water containing high levels of acrylamide over a long period of time could have problems with their nervous system or blood, and may have an increased risk of getting cancer.
- (26) Alachlor. Some people who drink water containing alachlor in excess of the MCL over many years could have problems with their eyes, liver, kidneys, or spleen, or experience anemia, and may have an increased risk of getting cancer.
- (27) Atrazine. Some people who drink water containing atrazine well in excess of the MCL over many years could experience problems with their cardiovascular system or reproductive difficulties.
- (28) Benzo(a)pyrene [PAH]. Some people who drink water containing benzo(a)pyrene in excess of the MCL over many years may experience reproductive difficulties and may have an increased risk of getting cancer.
- (29) Carbofuran. Some people who drink water containing carbofuran in excess of the MCL over many years could experience problems with their blood, or nervous or reproductive systems.
- (30) Chlordane. Some people who drink water containing chlordane in excess of the MCL over many years could experience problems with their liver or nervous system, and may have an increased risk of getting cancer.
- (31) Dalapon. Some people who drink water containing dalapon well in excess of the MCL over many years could experience minor kidney changes.
- (32) Di (2-ethylhexyl) adipate. Some people who drink water containing di (2-ethylhexyl) adipate well in excess of the MCL over many years could experience general toxic effects or reproductive difficulties.
- (33) Di (2-ethylhexyl) phthalate. Some people who drink water containing di (2-ethylhexyl) phthalate in excess of the MCL over many years may have problems with their liver, or experience reproductive difficulties, and may have an increased risk of getting cancer.
- (34) Dibromochloropropane (DBCP). Some people who drink water containing DBCP in excess of the MCL over many years could experience reproductive difficulties and may have an increased risk of getting cancer.
- (35) Dinoseb. Some people who drink water containing dinoseb well in excess of the MCL over many years could experience reproductive difficulties.
- (36) Diquat. Some people who drink water containing diquat in excess of the MCL over many years could get cataracts.
- (37) Dioxin (2,3,7,8-TCDD). Some people who drink water containing dioxin in excess of the MCL over many years could experience reproductive difficulties and may have an increased risk of getting cancer.
- (38) Endothall. Some people who drink water containing endothall in excess of the MCL over many years could experience problems with their stomach or intestines.

- (39) Endrin. Some people who drink water containing endrin in excess of the MCL over many years could experience liver problems.
- (40) Epichlorohydrin. Some people who drink water containing high levels of epichlorohydrin over a long period of time could experience stomach problems, and may have an increased risk of getting cancer.
- (41) Ethylene dibromide. Some people who drink water containing ethylene dibromide in excess of the MCL over many years could experience problems with their liver, stomach, reproductive system, or kidneys, and may have an increased risk of getting cancer.
- (42) Glyphosate. Some people who drink water containing glyphosate in excess of the MCL over many years could experience problems with their kidneys or reproductive difficulties.
- (43) Heptachlor. Some people who drink water containing heptachlor in excess of the MCL over many years could experience liver damage and may have an increased risk of getting cancer.
- (44) Heptachlor epoxide. Some people who drink water containing heptachlor epoxide in excess of the MCL over many years could experience liver damage, and may have an increased risk of getting cancer.
- (45) Hexachlorobenzene. Some people who drink water containing hexachlorobenzene in excess of the MCL over many years could experience problems with their liver or kidneys, or adverse reproductive effects, and may have an increased risk of getting cancer.
- (46) Hexachlorocyclopentadiene. Some people who drink water containing hexachlorocyclopentadiene well in excess of the MCL over many years could experience problems with their kidneys or stomach.
- (47) Lindane. Some people who drink water containing lindane in excess of the MCL over many years could experience problems with their kidneys or liver.
- (48) Methoxychlor. Some people who drink water containing methoxychlor in excess of the MCL over many years could experience reproductive difficulties.
- (49) Oxamyl [Vydate]. Some people who drink water containing oxamyl in excess of the MCL over many years could experience slight nervous system effects.

- (50) PCBs [Polychlorinated biphenyls]. Some people who drink water containing PCBs in excess of the MCL over many years could experience changes in their skin, problems with their thymus gland, immune deficiencies, or reproductive or nervous system difficulties, and may have an increased risk of getting cancer.
- (51) Pentachlorophenol. Some people who drink water containing pentachlorophenol in excess of the MCL over many years could experience problems with their liver or kidneys, and may have an increased risk of getting cancer.
- (52) Picloram. Some people who drink water containing picloram in excess of the MCL over many years could experience problems with their liver.
- (53) Simazine. Some people who drink water containing simazine in excess of the MCL over many years could experience problems with their blood.
- (54) Toxaphene. Some people who drink water containing toxaphene in excess of the MCL over many years could have problems with their kidneys, liver, or thyroid, and may have an increased risk of getting cancer.

Volatile Organic Contaminants:

- (55) Benzene. Some people who drink water containing benzene in excess of the MCL over many years could experience anemia or a decrease in blood platelets, and may have an increased risk of getting cancer.
- (56) Carbon Tetrachloride. Some people who drink water containing carbon tetrachloride in excess of the MCL over many years could experience problems with their liver and may have an increased risk of getting cancer.
- (57) Chlorobenzene. Some people who drink water containing chlorobenzene in excess of the MCL over many years could experience problems with their liver or kidneys.
- (58) o-Dichlorobenzene. Some people who drink water containing o-dichlorobenzene well in excess of the MCL over many years could experience problems with their liver, kidneys, or circulatory systems.
- (59) p-Dichlorobenzene. Some people who drink water containing p-dichlorobenzene in excess of the MCL over many years could experience

- anemia, damage to their liver, kidneys, or spleen, or changes in their blood.
- (60) 1,2-Dichloroethane. Some people who drink water containing 1,2-dichloroethane in excess of the MCL over many years may have an increased risk of getting cancer.
- (61) 1,1-Dichloroethylene. Some people who drink water containing 1,1-dichloroethylene in excess of the MCL over many years could experience problems with their liver.
- (62) cis-1,2-Dichloroethylene. Some people who drink water containing cis-1,2-dichloroethylene in excess of the MCL over many years could experience problems with their liver.
- (63) trans-1,2-Dichloroethylene. Some people who drink water containing trans-1,2-dichloroethylene well in excess of the MCL over many years could experience problems with their liver.
- (64) Dichloromethane. Some people who drink water containing dichloromethane in excess of the MCL over many years could have liver problems and may have an increased risk of getting cancer.
- (65) 1,2-Dichloropropane. Some people who drink water containing 1,2-dichloropropane in excess of the MCL over many years may have an increased risk of getting cancer.
- (66) Ethylbenzene. Some people who drink water containing ethylbenzene well in excess of the MCL over many years could experience problems with their liver or kidneys.
- (67) Styrene. Some people who drink water containing styrene well in excess of the MCL over many years could have problems with their liver, kidneys, or circulatory system.
- (68) Tetrachloroethylene. Some people who drink water containing tetrachloroethylene in excess of the MCL over many years could have problems with their liver, and may have an increased risk of getting cancer.
- (69) 1,2,4-Trichlorobenzene. Some people who drink water containing 1,2,4-trichlorobenzene well in excess of the MCL over many years could experience changes in their adrenal glands.
- (70) 1,1,1-Trichloroethane. Some people who drink water containing 1,1,1-trichloroethane in excess of the MCL over many years could experience problems with their liver, nervous system, or circulatory system.
- (71) 1,1,2-Trichloroethane. Some people who drink water containing 1,1,2-trichloroethane well in excess of the MCL over many years could have problems with their liver, kidneys, or immune systems.
- (72) Trichloroethylene. Some people who drink water containing trichloroethylene in excess of the MCL over many years could experience problems with their liver and may have an increased risk of getting cancer.
- (73) THMs [Total Trihalomethanes]. Some people who drink water containing trihalomethanes in excess of the MCL over many years may experience problems with their liver, kidneys, or central nervous systems, and may have an increased risk of getting cancer.
- (74) Toluene. Some people who drink water containing toluene well in excess of the MCL over many years could have problems with their nervous system, kidneys, or liver.
- (75) Vinyl Chloride. Some people who drink water containing vinyl chloride in excess of the MCL over many years may have an increased risk of getting cancer.
- (76) Xylenes. Some people who drink water containing xylenes in excess of the MCL over many years could experience damage to their nervous system.
- (77) HAA5 (Haloacetic Acids). Some people who drink water containing haloacetic acids in excess of the MCL over many years may have an increased risk of getting cancer.
- (78). Total Organic Carbon. Total organic carbon (TOC) has no health effects. However, total organic carbon provides a medium for the formation of disinfection byproducts. These byproducts include trihalomethanes (THMs) and haloacetic acids (HAAs). Drinking water containing these byproducts in excess of the MCL may lead to adverse health effects, liver or kidney problems, or nervous system effects, and may lead to an increase risk of getting cancer.

Pelham Water WORKS

Water is purchased from Shelby County
Water System to serve your area.

2009 Annual Drinking Water Quality Report



PRSRT STD
US Postage
PAID
Birmingham, AL
Permit #40

Annual Drinking Water Quality Report

PELHAM WATER WORKS

We are very pleased to provide you with this year's Annual Water Quality Report. We want to keep you informed about the excellent water and services delivered to you over the past year. Our goal is and always has been, to provide you a safe and dependable supply of drinking water. We purchase water from Shelby County Water Services to serve your area. The sources of the water are the Talladega/Shelby Water Treatment Plant and the Shelby County South Water Treatment Plant. The water produced from those sources comes from the Coosa River.

Pelham Water Works and Shelby County Water Services routinely monitor for constituents in your drinking water according to Federal and State laws. The Chemical Monitoring Data Information in this report has been provided to Pelham Water Works by Shelby County Water Services. The tables show the results of monitoring for the period of January 1st to December 31st of 2009.

We are pleased to report that our drinking water is safe and meets federal and state requirements.

If you have any questions about this report or concerning your water utility, please contact the City of Pelham's Public Works Director, Mr. Eddy Jowers at Pelham Water Works, 205-620-6413. We want our valued customers to be informed about their water utility. If you want to attend any of our regularly scheduled City Council Meetings, they are on the 1st and 3rd Monday of each month. Mayor Don Murphy is the Superintendent of the Water Works and the City Council members serve as the Water Board. The Council Members include, Mike Dickens, Teresa Nichols, PhD, Bill Meadows, Steve Powell and Karyl Rice.

DEFINITIONS

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Non-Detects (ND) - laboratory analysis indicates that the constituent is not present.

Not Tested (NT) - no testing was required during this monitoring period.

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

Secondary Contaminant Monitoring

Contaminant	Secondary MCL	Results Talladega/Shelby WTP	Results Shelby Co. South WTP	Noticeable Effects above the Secondary MCL
Aluminum	0.05 to 0.2 mg/L	153	NT	Colored water
Chloride	250 mg/L	12.5	NT	Salty taste
Color	15 color units	5	NT	Visible tint
Copper	1.0 mg/L	.0027	.04	Metallic taste; blue-green staining
Iron	0.3 mg/L	ND	NT	Rusty color; sediment; metallic taste; reddish or orange staining
Manganese	0.05 mg/L	4.7	NT	Black to brown color; black staining; bitter metallic taste
Odor	3 TON (threshold odor number)	0	NT	"rotten-egg", musty or chemical smell
Silver	0.1 mg/L	ND	NT	Skin discoloration; graying of the white part of the eye
Sulfate	250 mg/L	6.49	6.17	Salty taste
Total Dissolved Solids (TDS)	500 mg/L	50	NT	Hardness; deposits; colored water; staining; salty taste
Zinc	5 mg/L	ND	NT	Metallic taste

Residual Chlorine in the Distribution System Ranged from 0.60 mg/L to 2.10 mg/L

Parts per trillion (ppt) or Nanograms per liter (nanograms/l) - one part per trillion corresponds to one minute in 2,000,000 years, or a single penny in \$10,000,000,000.

Parts per quadrillion (ppq) or Picograms per liter (picograms/l) - one part per quadrillion corresponds to one minute in 2,000,000,000 years or one penny in \$10,000,000,000,000.

Picocuries per liter (pCi/L) - picocuries per liter is a measure of the radioactivity in water.

Millirems per year (mrem/yr) - measure of radiation absorbed by the body.

Million Fibers per Liter (MFL) - million fibers per liter is a measure of the presence of asbestos fibers that are longer than 10 micrometers.

Nephelometric Turbidity Unit (NTU) - nephelometric turbidity unit is a measure of the clarity of water. Turbidity in excess of 5 NTU is just noticeable to the average person.

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Treatment Technique (TT) - (mandatory language) A treatment technique is a required process intended to reduce the level of a contaminant in drinking water.

Maximum Contaminant Level - (mandatory language) The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal - (mandatory language) The "Goal" (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level Goal or MRDLG - The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Maximum Residual Disinfectant Level or MRDL - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

RAA - Running annual average

LRAA - Locational running annual average.

WHAT DOES THIS INFORMATION MEAN?

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and radioactive material, and it can pick up substances resulting from the presence of animals or from human activity.

MCL's are set at very stringent levels. To understand the possible health effects described for many regulated constituents, a person would have to drink 2 liters of water every day at the MCL level for a lifetime to have a one-in-a-million chance of having the described health effect.

Some people may be more vulnerable to contaminants in drinking water than the general population. People who are immuno-compromised such as cancer patients undergoing chemotherapy, organ transplant recipients, HIV/AIDS positive or other immune system disorders, some elderly, and infants can be particularly at risk from infections. People at risk should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials of components associated with service lines and home plumbing. Pelham Water Works is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

In our continuing efforts to maintain a safe and dependable water supply it may be necessary to make improvements in your water system. The costs of these improvements may be reflected in the rate structure. Rate adjustments may be necessary in order to address these improvements.

We at Pelham Water Works and Shelby County Water Services work around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

TEST RESULTS 2009 unless noted

Contaminant	Violation Y/N	Talladega/Shelby WTP Level Detected	Shelby Co. South WTP Level Detected	Unit Measurement	MCLG	MCL	Likely Source of Contamination
Microbiological Contaminants							
1. Total Coliform Bacteria	N	ND	ND		0	presence of coliform bacteria in 5% of monthly samples	Naturally present in the environment
2. Fecal coliform and E.coli	N	ND	ND		0	a routine sample and repeat sample are total coliform positive, and one is also fecal coliform or E. coli positive	Human and animal fecal waste
3. Turbidity	N	0.5	0.3	Ntu	n/a	TT	Soil runoff
Radioactive Contaminants							
4. Beta/photon emitters	N	ND	ND	mrem/yr	0	4	Decay of natural and man-made deposits
5. Alpha emitters	N	<1.0	ND	pCi/L	0	15	Erosion of natural deposits
6. Combined radium	N	<0.9	ND	pCi/L	0	5	Erosion of natural deposits
Inorganic Contaminants							
7. Antimony	N	ND	ND	ppb	6	6	Discharge from petroleum refineries; fire retardants; ceramics; electronics; solder
8. Arsenic	N	ND	ND	ppb	n/a	50	Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes
9. Asbestos	N	ND	ND	MFL	7	7	Decay of asbestos cement water mains; erosion of natural deposits
10. Barium	N	21	20	ppb	2000	2000	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
11. Beryllium	N	.4	0.3	ppb	4	4	Discharge from metal refineries and coal-burning factories; discharge from electrical, aerospace, and defense industries
12. Cadmium	N	ND	ND	ppb	5	5	Corrosion of galvanized pipes; erosion of natural deposits; discharge from metal refineries; runoff from waste batteries and paints
13. Chromium	N	1	ND	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N	2.7	40	ppb	1300	AL= 1300	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
15. Cyanide	N	2.72	ND	ppb	200	200	Discharge from steel/metal factories; discharge from plastic and fertilizer factories
16. Fluoride	N	1140	1200	ppb	4000	4000	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	ND	ND	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
18. Mercury (inorganic)	N	ND	ND	ppb	2	2	Erosion of natural deposits; discharge from refineries and factories; runoff from landfills; runoff from cropland
19. Nitrate (as Nitrogen)	N	320	500	ppb	10000	10000	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
20. Nitrite (as Nitrogen)	N	236	ND	ppb	1000	1000	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
21. Selenium	N	ND	ND	ppb	50	50	Discharge from petroleum and metal refineries; erosion of natural deposits; discharge from mines
22. Thallium	N	ND	ND	ppb	0.5	2	Leaching from ore-processing sites; discharge from electronics, glass, and drug factories
Synthetic Organic Contaminants including Pesticides and Herbicides							
23. 2,4-D	N	ND	ND	ppb	70	70	Runoff from herbicide used on row crops
24. 2,4,5-TP (Silvex)	N	ND	ND	ppb	50	50	Residue of banned herbicide
25. Acrylamide	N	ND	ND		0	TT	Added to water during sewage/wastewater treatment
26. Alachlor	N	ND	ND	ppb	0	2	Runoff from herbicide used on row crops
27. Atrazine	N	ND	ND	ppb	3	3	Runoff from herbicide used on row crops
28. Benzo(a)pyrene (PAH)	N	ND	ND	nanograms/l	0	200	Leaching from linings of water storage tanks and distribution lines
29. Carbofuran	N	ND	ND	ppb	40	40	Leaching of soil fumigant used on rice and alfalfa
30. Chlordane	N	ND	ND	ppb	0	2	Residue of banned termiticide
31. Dalapon	N	ND	ND	ppb	200	200	Runoff from herbicide used on rights of way
32. Di(2-ethylhexyl) adipate	N	ND	2.91	ppb	400	400	Discharge from chemical factories
33. Di(2-ethylhexyl) phthalate	N	ND	ND	ppb	0	6	Discharge from rubber and chemical factories
34. Dibromochloropropane	N	ND	ND	nanograms/l	0	200	Runoff/leaching from soil fumigant used on soybeans, cotton, pineapples, and orchards
35. Dinoseb	N	ND	ND	ppb	7	7	Runoff from herbicide used on soybeans and vegetables
36. Diquat	N	ND	ND	ppb	20	20	Runoff from herbicide use
37. Dioxin [2,3,7,8-TCDD]	N	ND	ND	picograms/l	0	30	Emissions from waste incineration and other combustion; discharge from chemical factories
38. Endothall	N	ND	ND	ppb	100	100	Runoff from herbicide use
39. Endrin	N	ND	ND	ppb	2	2	Residue of banned insecticide
40. Epichlorohydrin	N	ND	ND		0	TT	Discharge from industrial chemical factories; an impurity of some water treatment chemicals
41. Ethylene dibromide	N	ND	ND	nanograms/l	0	50	Discharge from petroleum refineries
42. Glyphosate	N	ND	ND	ppb	700	700	Runoff from herbicide use
43. Heptachlor	N	ND	ND	nanograms/l	0	400	Residue of banned termiticide
44. Heptachlor epoxide	N	ND	ND	nanograms/l	0	200	Breakdown of heptachlor
45. Hexachlorobenzene	N	ND	ND	ppb	0	1	Discharge from metal refineries and agricultural chemical factories
46. Hexachlorocyclopentadiene	N	ND	ND	ppb	50	50	Discharge from chemical factories
47. Lindane	N	ND	ND	nanograms/l	200	200	Runoff/leaching from insecticide used on cattle, lumber, gardens
48. Methoxychlor	N	ND	ND	ppb	40	40	Runoff/leaching from insecticide used on fruits, vegetables, alfalfa, livestock
49. Oxamyl [Vydate]	N	ND	ND	ppb	200	200	Runoff/leaching from insecticide used on apples, potatoes and tomatoes
50. PCBs [Polychlorinated biphenyls]	N	ND	ND	nanograms/l	0	500	Runoff from landfills; discharge of waste chemicals
51. Pentachlorophenol	N	ND	ND	ppb	0	1	Discharge from wood preserving factories
52. Picloram	N	ND	ND	ppb	500	500	Herbicide runoff
53. Simazine	N	ND	ND	ppb	4	4	Herbicide runoff
54. Toxaphene	N	ND	ND	ppb	0	3	Runoff/leaching from insecticide used on cotton and cattle
Volatile Organic Contaminants							
55. Benzene	N	ND	ND	ppb	0	5	Discharge from factories; leaching from gas storage tanks and landfills
56. Carbon tetrachloride	N	ND	ND	ppb	0	5	Discharge from chemical plants and other industrial activities
57. Chlorobenzene	N	ND	NT	ppb	100	100	Discharge from chemical and agricultural chemical factories
58. o-Dichlorobenzene	N	ND	ND	ppb	600	600	Discharge from industrial chemical factories
59. p-Dichlorobenzene	N	ND	ND	ppb	75	75	Discharge from industrial chemical factories
60. 1,2 - Dichloroethane	N	ND	ND	ppb	0	5	Discharge from industrial chemical factories
61. 1,1 - Dichloroethylene	N	ND	ND	ppb	7	7	Discharge from industrial chemical factories
62. cis-1,2-Dichloroethylene	N	ND	ND	ppb	70	70	Discharge from industrial chemical factories
63. trans -1,2 -Dichloroethylene	N	ND	ND	ppb	100	100	Discharge from industrial chemical factories
64. Dichloromethane	N	ND	ND	ppb	0	5	Discharge from pharmaceutical and chemical factories
65. 1,2-Dichloropropane	N	ND	ND	ppb	0	5	Discharge from industrial chemical factories
66. Ethylbenzene	N	ND	ND	ppb	700	700	Discharge from petroleum refineries
67. Styrene	N	ND	ND	ppb	100	100	Discharge from rubber and plastic factories; leaching from landfills
68. Tetrachloroethylene	N	ND	ND	ppb	0	5	Leaching from PVC pipes; discharge from factories and dry cleaners
69. 1,2,4 -Trichlorobenzene	N	ND	ND	ppb	70	70	Discharge from textile-finishing factories
70. 1,1,1 - Trichloroethane	N	ND	ND	ppb	200	200	Discharge from metal degreasing sites and other factories
71. 1,1,2 -Trichloroethane	N	ND	ND	ppb	3	5	Discharge from industrial chemical factories
72. Trichloroethylene	N	ND	ND	ppb	0	5	Discharge from metal degreasing sites and other factories
73. TTHM (RAA) [Total trihalomethanes]	N	22.5	35	ppb	0	80	By-product of drinking water chlorination
74. Toluene	N	ND	ND	ppb	1	1	Discharge from petroleum factories
75. Vinyl Chloride	N	ND	ND	ppb	0	2	Leaching from PVC piping; discharge from plastics factories
76. Xylenes	N	ND	ND	ppb	10000	10000	Discharge from petroleum factories discharge from chemical factories
77. HAA5 (RAA) (Haloacetic Acids)	N	20.8	31.4	ppb	0	60	By product of drinking water chlorination
78. TOC (Total Organic Carbon)	N	2.6	2.24	ppm	N/A	TT	Naturally present in the environment

Pelham Water Works monitored for Stage 1 and 2 Disinfection By-Products in the distribution system during 2009.

Contaminant	Violation Y/N	Level Detected	Unit Measurement	MCLG	MCL	Likely Source of Contamination
TTHM [Total trihalomethanes]	N	26-76.7	ppb	0	80	By-product of drinking water chlorination
HAA5 (Haloacetic Acids)	N	12-60	ppb	0	60	By product of drinking water chlorination